

January 25, 2023

*East Providence – Riverside Middle School Window Replacement Project*

PRE-BID RFI QUESTIONS & RESPONSES

1. We need the exact make-up of the 1-5/16" thick hurricane resistant glass for the Riverside Middle School?

Answer: The assembly shall consist of:

- 1/4" clear tempered glass w/ low-e on surface #2
- 1/2" air space
- 1/4" clear annealed
- PVD .060 clear
- 1/4" clear tempered

2. The spec calls for 1600UT which is not IR. I can modify with the IR pressure plate to accept the 1-5/16" glass but the system has not been tested for such. If they must have the tested IR1600 they will lose the thermal capacity.

Answer: Provide IR1600

**REMINDER– RFP Submission Deadline is Thursday, February 9<sup>th</sup>, 2023, at 10:00am. There will be a public bid opening immediately following the submission deadline at 1998 Pawtucket Avenue, East Providence, RI.**

117 Metro Center Boulevard, Suite 1002  
Warwick, RI 02886  
O: +1-401-214-3168 |