



East Providence School Department
RFP# EPSD.DISTRICT.2023.006
Oldham Classroom Re-Configuration

ADDENDUM #3

Q&A

Question

I am hoping to get a few answers on the doors that are proposed. I didn't see a door schedule. Is there further information or are we just to use something that is similar to existing?

Answer

Door specifications are below:

Door size 36"x84"

90 Min Fire rated

6"x27" glass window with 3m Film installed, or laminated glass

Knock down Frame with 4 7/8" width to accept 5/8" fire code sheetrock on 2x4 metal stud wall

Oak finish

Door hardware to be Sargent classroom function door locks with ADA style handles.